

DC510 - DC550

Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655 116
F : +44 (0) 1925 655 419
E : warrington@exova.com
W: www.exova.com



Testing. Advising. Assuring.

Executive Summary

Objective

This report presents an appraisal of the fire resistance performance of single-acting timber doorsets when fitted with Meroni 'DC510' or 'DC550' concealed door closers, if tested in accordance with EN 1634-1.

Report Sponsor

Serrature Meroni SpA

Address

**via Giulio Natta, 16
20030 Lentate sul Seveso - MB - Italy**

Summary of Conclusions

Should the recommendations given in this report be followed, it can be concluded that the Meroni 'DC510' or 'DC550' concealed door closers may be fitted to previously tested, by a Notified laboratory, (or assessed by Exova Warringtonfire) insulated doorsets, to provide 60 minutes integrity and insulation performance, if tested in accordance with EN 1634-1.

Valid until

1st March 2016

This report may only be reproduced in full. Extracts or abridgements of reports shall not be published without permission of Exova Warringtonfire.

Title:

The Fire Resistance Performance Of Single-Acting Timber and Mineral Composite Based Doorsets When Fitted With Meroni DC510 And DC550 Concealed Door Closers

Report No:

199278B

Prepared for:

Serrature Meroni SpA

**via Giulio Natta, 16
20030 Lentate sul
Seveso - MB - Italy**

Date:

3rd February 2011